



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/09/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-50	OLR ACTED	RESET DONE	06:20:00	06:30:00	
2	OHP	CO-15	OLR ACTED	RESET DONE	09:35:00	09:40:00	
3	OHP	CO-29	OLR ACTED	RESET DONE	09:35:00	09:40:00	
4	OHP	TT-4 ON CO-3A	REPORTED TT-4 NOT MOVE CHECKED AND FOUND PCRD CABLE B PHASE INSULATION DAMAGED	B PHASE TAPPING WAS DONE THAN OK	07:30:00	08:00:00	
5	OHP	CO-36A	REPORTED START COMMEND NOT TAKEN CHECKED ARC CHUTE ZSS SUPPLY PROBLEM	ARC CHUTE PROPERLY FIXED AND ZSS SUPPLY TIGHT THAN OK	11:00:00	11:30:00	
6	CHP	CC-26A	OLR ACTED	RESET DONE	07:00:00	07:05:00	
7	CHP	CC-26A	REPORTED STOPPING ON ZSS CHECKED ZSS CAGE STUCK UP WITH STONE	STONE REMOVED THAN OK	07:15:00	07:25:00	
8	CHP	TT ON CC-26	TT NOT MOVE CHECKED MPCB TRIP	MPCB MADE ON THAN OK	13:00:00	13:05:00	
9	CHP	CC-26	OLR ACTED	RESET DONE	08:00:00	08:10:00	
10	CHP	CC-29 ON CC-111	REPORTED POSITION INDICATION MISSING	POSITION SENSOR CLEANED THAN OK	11:30:00	11:40:00	
11	CHP	CC-13,CC-14	REPORTED NOT HEALTHY CHECKED CONTROL MCB TRIP	MCB MADE ON THAN OK	11:40:00	11:50:00	
12	CHP	CC-51	MPD OLR ACTED (8TIMES)	RESET DONE	09:40:00	13:05:00	
13	CHP	CC-54	OLR ACTED	RESET DONE	10:25:00	10:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/09/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-104 SCR-9	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	10:10:00	10:25:00	