



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/06/2025

Shift: A

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO9	Electronic olr trip	Reset done	12:00:00	12:10:00	
2	CHP	SCR3 on CC38	Lower luffing limit bypassed as per operational request	After finishing reclaiming put back in ckt	09:50:00	10:20:00	
3	CHP	CC33	No t healthy found olr acted	Reset done	10:00:00	10:05:00	
4	CHP	SCR5 on CC32	MCCB tripped chute jammed BC offcentering	Informed to mechanical regarding jamming of deck sheets after that made on	06:45:00	07:00:00	
5	CHP	SCR6 on CC40	slewing not working found jamming in slewing pinion area	Informed to operation after cleaning found healthy	07:05:00	07:15:00	
6	CHP	CC201	relay tripped	Reset done	06:20:00	06:30:00	
7	CHP	SCR5 on CC32	LT not working found drive tripped on over load	Reset done	08:00:00	08:10:00	
8	CHP	R1 on CC31	BC not running found coal struck in ZSS cage	Coal removed then ok	08:00:00	08:20:00	
9	CHP	CC44	OLR tripped due to jamming	informed to operation for cleaning Reset done	09:25:00	10:30:00	
10	CHP	SCR1 on CC36	Luffing upper limit struck	made released then ok	13:20:00	13:30:00	
11	CHP	SCR10 on CC105	BC not running found nothig	Reset done in panel then ok	12:10:00	12:40:00	
12	CHP	SCR8 on CC112	Wrong complaint	cleared	11:05:00	11:15:00	
13	CHP	CC51	olr tripped	Reset done	10:25:00	10:30:00	
14	CHP	CC54	olr tripped 3 times	Reset done	11:30:00	12:15:00	
15	CHP	CC131	olr tripped 2 times	Reset done	10:45:00	11:20:00	