



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/05/2025

Area: CHP

| Equipment | Job |
|---------------------|--|
| CC 54 | Removed motor sent to ERS |
| JH C3 | LDB incoming MCB replaced |
| CC 25/26 Take up | Lighting improved |
| CC 15,19,22,113,132 | PPM was done |
| CC 104 SCR 9 | PCRD OT kept in ckt |
| R/Bay Stacker | Upper MCC to lower MCC power and control cables removed for mechanical job |