



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/08/2025

Area: CHP

Equipment	Job
CC 19	Control MCB replaced
CC 26A	Burnt motor coupling removed and sent to ERS
CC 38,39,40 Tail end	Lighting improved,replaced 3nos 70W fixtures and 2 nos 50W LED lamps
CC 222/223	Communication problem rectified and run the stream
SCR 1	New PLC panel fabrication done
CC 215,216,217,218,VS 2,VF2	PPM was done