



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/07/2025

Area: OHP

Equipment	Job
Processor-C and OCR HMI's	EPROM loading and warm restart is done. OCR HMI's wincc was reset.