



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/04/2025

Shift: B

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment     | Problem                                     | Action                | From                 | To                   | Remarks     |
|-------|------|---------------|---|-----------------------|----------------------|----------------------|-------------|
| 1     | OHP  | TBS ON CO 20  | RBC NOT RUNNING BELT SLIPPED DUE TO JAMMING | INFORMED TO OPERATION | 15:25:00             | 15:35:00             |             |
| 2     | OHP  | WOBR ON CO 26 | SLEWING NOT TAKING PLACE DRIVE TRPPED       | RESET                 | 15:40:00             | 16:00:00             |             |
| 3     | OHP  | TBS ON CO 22  | LBC STOPPING ON ZS PROBE DAMAGED            | PROBE REPLASD         | 15:45:00             | 16:15:00             |             |
| 4     | OHP  | TIS ON CO 29  | ZS PROBE DAMAGED                            | PROBE REPLACED        | 17:00:00             | 17:30:00             |             |
| 5     | OHP  | CO34          | OLR ACTED                                   | RESET                 | 18:00:00<br>18:15:00 | 18:05:00<br>18:30:00 |             |
| 6     | OHP  | CO33M         | OLR ACTED                                   | RESET                 | 19:00:00             | 19:10:00             |             |
| 7     | OHP  | WOBR ON CO25  | LT NOT TAKING PLACE MAIN CONTROL OFF        | CONTROL ON            | 19:30:00             | 19:35:00             |             |
| 8     | OHP  | WOBR ON CO 25 | B/C STOPPING ZS PROBE DAMAGED               | PROBE REPLACED        | 19:40:00             | 20:00:00             |             |
| 9     | OHP  | CO6A          | BRS NOT RESETTING                           | BY PASSED             | 21:00:00             | 21:30:00             | JOD IN LINE |
| 10    | CHP  | CC104 SCR 9   | SLEWING NOT WORKING DRIVE TRPPED            | RESET                 | 16:35:00             | 16:45:00             |             |
| 11    | CHP  | CC34 SCR 2    | B/C STOPPING FREQUENTLY SIGNAL PROBLEM      | INFORMED TO OPERATION | 19:00:00             | 20:00:00             |             |
| 12    | CHP  | CC36          | ZS PROBLEM                                  | PROBE CHANGED         | 21:15:00             | 21:30:00             |             |
| 13    | IOSA | OC 7A         | NOT RUNNING HVMCC 5 I/C 1 TRIPPED           | MADE ON               | 18:45:00             | 19:15:00             |             |