



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/09/2025

Shift: A

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO15	olr acted	reset done	08:25:00	08:30:00	
2	OHP	CO42A	BRS acted frequently checked found material falling from conveyer	Informed to operation	08:00:00	08:15:00	
3	OHP	BRC on CO28	LT not working, cable fall down	Winding done	08:30:00	09:00:00	
4	OHP	CO77	Belt scale acting and stopping conveyot	Offcentering and over load adviced to reduce load then ok	09:00:00	09:30:00	
5	OHP	BRC on CO28	LT not working in remote	Parameter changed from drive by G shift	09:30:00	09:40:00	No delay brc run on loacl
6	OHP	Co11 belt	olr acted	reset done	11:10:00	11:20:00	
7	OHP	CO11 carriage	olr acted	Reset done	11:10:00	11:15:00	
8	OHP	TBS on CO23	Luffing not working olr acted	Reset done	13:30:00	13:40:00	
9	OHP	CO11 belt	olr acted	reset done	12:30:00	12:40:00	
10	CHP	Cc51	MPD trip on olr stopping feeding conveyor 3 times	Reset done	07:25:00	07:27:00	09.15am to 09.17am:10.57am to 10.59am
11	CHP	CC54	tripped on olr	Reset done	07:20:00	07:25:00	
12	CHP	Cc113	stopped on ZSS due to belt slow down	Informed to mechanical and operation	10:15:00	10:20:00	
13	CHP	Cc49	ZSS not working return core not working	bypassed in IO rake may check further	10:00:00	10:05:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/09/2025

Shift: A

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP5	before coupling C clamp top bend	clamp replaced and given clearance	13:00:00	13:45:00	