



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/05/2025

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|---------------------------------|----------------------|----------------------|----------------|
| 1 | OHP | CO23 | BRS NOT RESETTING | BY PASSED | 08:20:00 | 08:35:00 | |
| 2 | OHP | CO33M | OLR ACTED | RESET | 08:30:00 10:30:00 | 08:40:00 10:45:00 | |
| 3 | OHP | BRC ON CO32 | B/C NOT RUNNING OLR ACTED | RESET | 09:00:00 | 09:45:00 | DUE TO JAMMING |
| 4 | OHP | TBS ON CO20 | LT NOT TAKING PLACE PCRD O/T ACTED | RELEASED | 10:00:00 | 10:15:00 | |
| 5 | OHP | WOBR ON CO25 | B/C NOT RUNNING ZS CAGE STUCK WITH STONE | STONE REMOVED THAN OK | 12:15:00 | 12:35:00 | |
| 6 | CHP | CC54 | OLR ACTED | RESET | 10:15:00 | 10:30:00 | |
| 7 | CHP | CC40 | OLR ACTED | RESET | 11:00:00 | 11:10:00 | |
| 8 | CHP | CC 34 S1 | SLEWING NOT WORKING DUE TO JAMMING | INFORMED TO OPERATION | 11:30:00 | 11:50:00 | |
| 9 | CHP | CC 34 SCR 5 | B/C NOT RUNNING MCCB TRIPPED | MADE ON | 12:00:00 | 12:20:00 | |
| 10 | CHP | CC31 S3 | LT NOT TAKING PLACE U/T LIMIT ACTED | RELEASED THAN OK | 12:25:00 13:30:00 | 12:45:00 13:45:00 | |
| 11 | CHP | CC31 | BRS | BY PASSED OPERATION REQUIREMENT | 13:40:00 | 13:50:00 | |
| 12 | CHP | CC 39 SCR 7 | LT NOT TAKING PLACE CHECKED NO PROBLEM | FAULT RESET THAN OK | 07:10:00 | 07:35:00 | |
| 13 | WT | OT 4 | LIMIT SWITCH CABLE GOT CUT | JOINT DONE | 11:15:00 | 11:25:00 | |