



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/08/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co-5a	L/LUFF NOT TAKING PLACE OLR ACTED	OLR RESET	07:15:00	07:30:00	
2	OHP	WOBR ON CO-26	B/W NOT RUNNING MPCB TRIP (2TIMES)	RESET	09:30:00 10:10:00	09:45:00 10:20:00	
3	OHP	TBS ON CO 5A	LT NOT TAKING PLACE DUE TO PCRD CABLE OVER LAPPING	PCRD LAYERING ADJUSTED	10:00:00	10:30:00	
4	OHP	CO 29	REPORTED RED OLR ACTED	RESET	10:30:00	10:40:00	
5	OHP	CO-84	OLR ACTED	RESET	12:20:00	12:30:00	
6	OHP	CO-33M	OLR ACTED	RESET	12:50:00	13:00:00	
7	CHP	CC 54	OLR ACTED(3TIMES)	RESET	07:40:00	07:50:00	10:40,11:30
8	CHP	CC-51	STOPPING ON ZS DUE TO JAMMING	INFORM TO OPERATION	11:30:00	11:50:00	
9	CHP	CC-52	OLR ACTED (2TIMES)	RESET	12:10:00 12:50:00	12:20:00 13:00:00	
10	CHP	CC-26 F/G	MPCB TRIP	RESET	13:15:00	13:20:00	
11	CHP	CC-40 SCR-3	B/C not running	Signal missing.LT forward done and tested okay	09:30:00	09:40:00	
12	CHP	CC-33 SCR-4	B/W not running	Low charge pressure problem. Bypassed and informed to hydraulic in charge	10:00:00	10:10:00	informed to mechanical
13	WT	OP-1	Reported no movement	Between Column no.11 and 12 insulator failed. Packing provided and tested okay	13:00:00	14:00:00	
14	WT	CO-3(B/D)	Reported not healthy	OLR acted. reset done(2 times)	07:00:00 10:00:00	07:15:00 10:15:00	
15	WT	OC-1A	Reported not healthy	OLR acted. reset done	10:15:00	10:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/08/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OT-2	Initial not coming	Rollers got jammed.	06:30:00	06:45:00	informed to operation