



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 31 BRC	b/c not running,ZSS acted,module	module replaced	09:00:00	09:20:00	
2	OHP	CO 29	OLR acted	reset	08:20:00	08:30:00	
3	OHP	CO 31 BRC	b/c olr acted ,powerTB cable loose connection	reset,tightened	10:25:00	10:35:00	
4	OHP	WOBR on CO 25	b/c olr acted,off center of belt	reset	13:30:00	13:40:00	
5	OHP	RSCO9A(C)	olr acted	reset	07:20:00	07:30:00	
6	CHP	CC 32 R1	b/c not running,zss interlock cage stucked	made free	06:50:00	07:00:00	
7	CHP	CC 105 SCR10	b/c not running,K5 relay problem	relay contact bypass	07:28:00	07:50:00	
8	CHP	cc 45	OLr acted	reset	11:40:00	11:45:00	
9	CHP	CC 51	OLR acted	reset	10:40:00	10:45:00	
10	CHP	CC 39 SCR1	pcrd cable fallen gear box problem	informed operation	12:20:00	12:30:00	
11	CHP	CC 19	BRS acted	resetted	06:35:00	06:40:00	