



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/07/2025

Shift: B

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT2	LT not moving found MPCB trip	made on	15:25:00	15:40:00	
2	OHP	TBS on CO24	LT not moving found found Luffing in down position	Luffing made up reclaiming position than ok	15:30:00	15:50:00	
3	OHP	BRC on CO34	BW2 not running found over tension over material ZSS acting	informed to operation After material cleaning ok	17:05:00	17:15:00	
4	OHP	CO35	OLR cated	Reset done	17:30:00	17:36:00	
5	OHP	Stacker on Co24	No drives running found operator cabin control off push button not pressed	Control on PB pressed by operator then ok	20:30:00	20:40:00	
6	CHP	SCR4 on Cc33	Slew not working found cabin side fault reset not done	fault reset done thenok	14:30:00	14:45:00	
7	CHP	CC201	Found red and pull card acted	reset done	18:20:00	18:30:00	
8	CHP	SCR4 on CC33	Lt not working found OT acted and cable over lapped and guide struck	tension limit released and informed to mechanical for guide adjustment	19:10:00	19:30:00	
9	CHP	CC203	Lighting found MCB and RCCB tripped 3rd no MCB ckt fault reset done	CKt need to be checked in G shift	18:50:00	19:00:00	
10	CHP	CC44	OLR tripped	Reset done	20:50:00	21:00:00	
11	CHP	CC53	TT flap gate motor MCCb tripped	Reset done	15:30:00	15:40:00	
12	CHP	CC54	Motor tripped in three times due to over load	Reset done	15:50:00	15:55:00	05.30pm to 05.35pm and 08.15pm to 8.20pm
13	CHP	CC114	ZSS cage damaged	New ZSS cage fixed then ok	18:00:00	18:01:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/07/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	RG2 chute vibrator	Found chute vibrator cable damaged	Cable rejoined then ok	18:00:00	18:01:00	
15	CHP	CO14	ZSS cabel damaged	Joint work done then ok	18:10:00	18:20:00	
16	CHP	CC9	Not movig found counter weight fallen and belt sheared	Shut down given and lighting provided	18:30:00	18:40:00	
17	CHP	CC26	flap gate problem loose contact	tightenedthen ok	19:00:00	19:10:00	