



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/10/2025

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 67	OLR ACTED	RESET	09:55:00	10:05:00	
2	OHP	CO 24 RED DUE TO NO SUPPLY FOR DMPR	CONTROL MCB TRIPPING DUE TO EARTH FAULT IN SPACE HEATER CORE	SPACE HEATER CORE REMOVED MADE IT ON	07:20:00	07:40:00	INFORMED TO G SHIFT
3	OHP	BEC ON CO 31	B/C OLR ACTED	RESET	10:10:00	10:20:00	
4	OHP	CO 26	OLR ACTED	RESET	11:50:00	12:00:00	
5	OHP	CO 85	B/S BYPASS LOOP LOOSE CONNECTION	TIGHTENED THEN OK	12:20:00	12:30:00	
6	OHP	RSCO 10A	CARRIAGE DRIVE TRIPPED	MADE IT ON	12:00:00	12:10:00	
7	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	09:30:00	09:35:00	
8	CHP	CC 52	FEEDING CONV CC 113 STOPPED	RESET	08:00:00	13:45:00	8 TIMES
9	CHP	CC 54	OLR ACTED	RESET	07:30:00	10:30:00	7 TIMES
10	CHP	SCR 10 LT	M2 TRIPPED DUE TO TRACK JAM	MRESET AND INFORMED TO OPRN	06:50:00	07:00:00	
11	CHP	SCR 8 ON CC 112	B/C ZSS ACTING DUE TO JAMMING	AFTER CLEAMNING OK	07:00:00	07:15:00	
12	CHP	SCR 6 ON CC 38 LT	M1 TRIPPED DUE TO TRACK JAMMING	RESET	11:30:00	11:35:00	
13	CHP	S3 ON CC 111	TUL C/S ACTED PROBE CLEANED	THEN OK	12:20:00	12:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/10/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	S3 ON CC 111 SLEW NOT WORKING	SLEW POWER KEPT OFF	MADE IT ON	12:20:00	12:40:00	
15	CHP	CC 111	B/S ACTED	BYPASSED	12:30:00	12:40:00	INFORMED TO G SHIFT
16	CHP	R1 ON CC 32	ZSS INTERLOCK CAGE STUCK	MADE IT FREE	12:40:00	12:50:00	
17	CHP	CC 28	OLR ACTED	RESET	12:30:00	12:35:00	