



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR (2TIMES)	RESET DONE	07:15:00 08:30:00	07:20:00 08:40:00	
2	OHP	TBS ON CO-20	LT NOT TAKING PLACE DRIVE TRIP	RESET DONE	07:45:00	08:00:00	
3	OHP	BRC ON CO-8A	REPORTED B/W-2 NOT RUNNING FOUND STONE STUCK UP INFORMED TO MECHANICAL	STONE REMOVED THAN OK	08:45:00	09:00:00	
4	OHP	TBS ON CO-20	REPORTED RBC NOT RUNNING FOUND CONTROL MCB TRIP	CONTROL MCB MADE ON	10:10:00	10:20:00	
5	OHP	CO-35	OLR ACTED	RESET DONE	10:30:00	10:40:00	
6	OHP	CO-63 (B/D)	MPCB TRIP	MADE ON	09:00:00	09:10:00	
7	OHP	BRC ON CO-8A	REPORTED PCRD NOT WINDING FOUND CHAIN AND GUIDE PROBLEM	PCRD GUIDE ADJUSTED AND CABLE PROPER LAYING WAS DONE WITH MECHANICAL	10:40:00	11:00:00	
8	OHP	TBS ON CO-20	LT NOT TAKING PLACE	L/B KEPT IN RECLAMING HIGHT THAN OK	12:30:00	12:45:00	
9	CHP	CC-41	OLR ACTED	RESET DONE	06:25:00	06:30:00	
10	CHP	CC-107	TRIPPED ON OLR	RESET DONE	08:25:00	08:30:00	
11	CHP	CC-125	OLR ACTED	RESET DONE	08:50:00	08:55:00	
12	CHP	CC-33 SCR-5	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	08:45:00	08:55:00	
13	CHP	CC-38 SCR-6	LT NOT TAKING PLACE FOUND M-2, M-3, M-5 OLR TRIP DUE TO TRACK JAMMING	AFTER CLEAR THE TRACK RESET DONE	10:45:00	11:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-112 SCR-8	SLEW NOT WORKING FOUND 30 LIMIT ACTED	LIMIT BYPASSED AS PER CCR INCHARGE	10:40:00	11:15:00	30 DEGREE LIMIT KEPT IN CIRCUIT AT 1410 HRS
15	WT	OP-7	NOT MOVE FOUND PUSHER LIMIT ACTED	RELEASED	10:00:00	11:10:00	