



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/09/2025

Shift: C

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT3 on BPC 2	control cable got opened,earthed,glass fuse blown	cable connected and insulated,fuse replaced	00:50:00	01:10:00	
2	OHP	CO 111(b)	olr acted	reset it on	01:00:00	01:05:00	
3	OHP	WOBR on co 29	LT not taking place,M3 mpcb tripped	made it on	00:00:00	00:12:00	
4	OHP	CO 26	olr acted	reset it done	03:00:00	03:15:00	3 times
5	OHP	CO 29	olr acted	reset	01:40:00	01:50:00	
6	CHP	CC49	ZSS sensor problem	New fixed	23:38:00	23:54:00	
7	CHP	SCR2 on CC34	ACB tripped	Reset and made on	23:17:00	23:31:00	
8	CHP	S3 on CC111	Light not glowing found cable got cut	cable rectification done	00:05:00	00:20:00	
9	CHP	SCR1 on Cc36	Slew not working	Wrong complaint	04:30:00	04:40:00	
10	CHP	SCR1 on CC36	Luffing not working found oil level low	Oil leakage informed to mechanical	05:05:00	05:15:00	
11	CHP	Cc108	olr acted	Reset done	05:00:00	05:05:00	
12	CHP	Cc54	olr acted	Reset done	00:02:00	00:05:00	05.15am to 05.20am:05.30am to 05.35am
13	CHP	TT3 on BPC2	Control cable got opened covered by materila and glass fuse blown	Cable connected properly and fuse replaced then ok	00:50:00	01:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC28 TT	chute sensor bypassed as per operational request	Bypassed	01:30:00	01:35:00	
15	WT	OT1	D1 tripped in PGF1 fault	reset it done	00:55:00	01:01:00	