



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/06/2025

Area: WT

Equipment	Job
OP 5	D2 motor checked , slip rings cleaning done and 3 nos brushes replaced and drive kept in circuit
OP 5	Trolley line , jumpers welding done for all three Bus bars @ col no 87
OP 3 and 5	after rake maintenance done , OP 3, all drives checked in de clutch position, found OK