



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-23	LT NOT TAKING PLACE CHECKED M-1 OLR ACTED	RESET	00:45:00	01:05:00	
2	OHP	TBS ON CO-23	LT NOT TAKING PLACE IN REMOTE MODE	Boom reclaiming height not there. Boom lifted and tested okay.	01:30:00	02:00:00	
3	OHP	BRC ON CO-30	CT NOT TAKING PLACE POWER MCCB TRIP	MCCB MADE ON	03:25:00	03:40:00	
4	OHP	BRC ON CO-30	LT NOT TAKING PLACE CHECKED DRIVE TRIP (3TIMES)	DRIVE RESET	04:30:00 05:00:00 05:30:00	04:40:00 05:10:00 05:40:00	
5	CHP	CC-114	OLR ACTED	RESET	23:10:00	23:20:00	
6	CHP	CC-54	OLR ACTED(4TIMES)	RESET	00:55:00	01:00:00	BETWEEN 12:55 TO 0400 AM
7	CHP	CC-51	REPORTED STOPPING ON ZSS CHECKED BELT MATERIAL OVER LOAD BELT NO MOMENT	INFORMED TO OPERATION	04:00:00	04:20:00	
8	CHP	CC-112 SCR-8	REPORTED ALL DRIVES NOT RUNNING CHECKED ACB TRIP	ACB MADE ON THAN OK	05:45:00	06:00:00	