



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR OON CO-6A	B/C OLR ACTED	RESET DONE	01:30:00	01:40:00	
2	OHP	CO-10A	OLR ACTED (3TIMES) DUE TO MATERIAL JAMMING	RESET DONE	01:35:00 03:50:00 23:35:00	01:45:00 04:00:00 23:45:00	
3	OHP	CO-34	OLR ACTED (2TIMES) DUE TO JAMMING	RESET DONE	01:10:00	01:30:00	
4	OHP	WOBR ON CO-29	SLEW NOT WORKING FOUND OLR ACTED	RESET DONE	02:35:00	02:45:00	
5	OHP	CO-43A	REPORTED NOT HEALTHY C/S ACTED DUE TO CHUTE JAMMING	AFTER CLEAN MATERIAL RESET DONE	04:45:00	05:00:00	
6	CHP	CC-37 SCR-7	SLEW NOT WORKING FOUND SPIDER BREAK FAIL ALARM ACTED	RESET DONE	02:20:00	02:40:00	
7	CHP	CC-38 SCR-6	SLEW NOT WORKING CHECKED AND FOUND MATERIAL JAMMING	INFORMED TO OPERATION	03:35:00	03:45:00	