



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 19	BRS bypass request by operation bcz of belt pieces	bypassed in IO rack	23:15:00	23:30:00	
2	OHP	BRC on CO 28	LT not working due to overtension acted	tension released	02:55:00	03:10:00	
3	OHP	CO 20	Yard side BRS bypass request by operation bcz of belt off centering	bypassed in module	03:20:00	03:30:00	
4	OHP	VS 2	Thermal OLR acted	reset done	04:30:00	04:45:00	
5	OHP	BRC on CO 33M	ZSS interlock indication missing while running	Check probe damaged , new probe replaced	04:30:00	04:55:00	
6	OHP	TBS on CO 22	LT not working	Drive overload acted , reset done	05:52:00	06:02:00	
7	CHP	CC 17	OLR acted	reset done	04:50:00	04:55:00	
8	CHP	CC 51	MPD tripped on overload	reset done	00:25:00	00:35:00	
9	CHP	CC 117	Tripped on overload	reset done	00:50:00 23:40:00	01:00:00 23:50:00	
10	CHP	CC 105 , SCR 7	LT not working due to overtension acted	tension released . Again problem comes, due to single phasing cable unwinded , rectified and winded properly	01:15:00 02:30:00	01:30:00 03:10:00	
11	CHP	CC 104 , SCR 9	LT not working due to PCRD overtension acted	tesnion released	01:50:00 02:55:00	02:05:00 03:15:00	
12	CHP	CC 201	Tripped on overload	reset done	03:50:00	04:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 31	Tripped on overload	reset done	04:50:00 05:10:00 05:50:00	05:05:00 05:25:00 05:55:00	
14	CHP	CC 107	Tripped on overload	reset done	05:10:00	02:25:00	
15	CHP	CC 32 , SCR 5	BC not running due to ZSS cage stucked with coal piece	coal removed , ZSS cage made free	05:10:00	05:30:00	