



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/07/2025

Area: IOSA

Equipment	Job
OC-13A , OC-14A	PPM DONE ON MOTORS.
OC-13A	ONE PULLCHORD SWITCH SHOWING OPERATED AND NOT GETTING HEALTHY. CONTACT NOT MAKING PROPERLY. RECIFIED SAME.
BRC AND WONR ( FLS)	HYDRAULIC POWER PACK XMD PANEL MAINTENANCE DONE.
OC-19A	BRS UNITS MAINTENANCE AND FEEDBACK CHECKING DONE.
BRC	BRAKE PANELS MADE READY AND CHECKING DONE AND SHIFTED TWO PANEL TO BRC CT PLATFORM FOR HARROWS EM BRAKES.
OC-18A	PPM DONE ON FIELD DEVICES.
OC-9A, OC-11A	BRS AND ZSS INSPECTION and FEEDBACK CHECKING DONE.