



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/10/2025

Area: WT

| Equipment | Job |
|---------------|---|
| EOT Crane (O) | Main hoist UP cantactor 2C1 replaced (,110A,240V ,BCH) |
| MIS | OT 1,2,3 and 4 hopper area light fittings cleaning done |
| OP 5 | After rake maintenance done, bottom C clamp adjusted |
| OP 4 | After rake maintenance done,2 nos lugs replaced in D6 |