



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/08/2025

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment       | Problem                       | Action   | From   | To   | Remarks  |
|-------|------|-----------------|-------------------------------|--|--|--|--|
| 1     | CHP  | CC-29           | Reported tripped              | OLR acted.Reset done   | 11:30:00                                     | 11:35:00                                     |  |
| 2     | CHP  | CC-51           | Feeding conveyor C-31 stopped | Due to MPD acted for CC-51                                   | 12:05:00                                     | 12:10:00                                     |  |
| 3     | CHP  | CC-35<br>SCR-1  | Slew not taking place         | Right limit acted.(2times).Released and tested okay.         | 07:10:00<br>10:05:00                         | 07:20:00<br>10:15:00                         |  |
| 4     | CHP  | CC-111 S-3      | slew not taking place         | Slew area jamming found                                      | 06:45:00                                     | 06:55:00                                     | Informed to operation .after cleaning done tested okay |
| 5     | CHP  | CC-34<br>SCR-2  | LT not taking place           | LT OT acted(4times).Released and tested okay                 | 09:10:00<br>09:50:00<br>10:40:00<br>11:25:00 | 09:18:00<br>10:00:00<br>10:50:00<br>11:35:00 |  |
| 6     | CHP  | CC-105<br>SCR-7 | Slew not taking place         | Spider break fail alarm in spider.Reset done and tested okay | 09:25:00                                     | 09:35:00                                     |  |
| 7     | CHP  | CC-41           | Reported tripped              | OLR acted.reset done   | 11:10:00                                     | 11:20:00                                     |  |
| 8     | CHP  | CC-104<br>SCR-9 | LT not moving                 | PCRD guide stuck.Made free and tested okay                   | 10:50:00                                     | 11:00:00                                     |  |
| 9     | CHP  | CC-104<br>SCR 9 | LT not taking place           | PCRD control MCB Tripped.Made on and tested okay             | 12:50:00                                     | 13:00:00                                     |  |