



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/10/2025

Area: OHP

| Equipment | Job |
|---------------------------|---|
| brc-5 on co-8a | bridge conveyor motor failed, motor changed with spare one and tested . |
| lc4,lc3,om-24 and jh O-14 | de watering is being done. |
| JH O-3 to O-4 | bay lighting circuit checked and restored illumination, |
| tt-3 and tt-2 on co-22 | proximity sensor is changed and restored in circuit. |
| co 76r,68 | motor and feeder side ppm is done. |