



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/10/2025

Area: CHP

Equipment	Job
SCR 8	Hydraulic system instrumentation switches maintenance was done
CC 201, 222,223	Belt scale maintenance was done
Coal complex	Rooms cleaning was done
CC 111	BS kept in ckt
CC 107/108/126/SCR 2	5nos 70W SV fixtures rectified and 120W LED fixture replaced
All JHs	De watering inspection was done
SCR 1	Slew motors power connections removed for mechanical work
CC 112,SCR 8	PPM was done
CC 25,26,26A,27,27A	BRS and CJB maintenance was done
JH C 3,15,16	Hoist and LDB panels maintenance was done
SCR 1	New PLC panel I/O wiring completed,PLC charged and tested for communication. Unwanted control wires removed from slew panel.