



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/09/2025

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment      | Problem                                  | Action                            | From     | To       | Remarks |
|-------|------|----------------|--|-----------------------------------|----------|----------|---------|
| 1     | OHP  | CO 66 OLR      | WIRE LOOSE IN RL5                        | TIGHTENED                         | 14:30:00 | 14:45:00 |         |
| 2     | OHP  | wbr on co-29   | MPCB TRIPPED                             | RESET DONE                        | 19:50:00 | 20:10:00 |         |
| 3     | CHP  | CC 54          | OLR ACTED                                | RESET                             | 16:00:00 | 16:10:00 |         |
| 4     | CHP  | SCR 4 ON CC 31 | PCRD CABLE FALLEN DUE TO GUIDE PROBLEM   | WINDING DONE AFTER MECH CLEARANCE | 15:30:00 | 16:00:00 |         |
| 5     | CHP  | R 1 ON CC 33   | SLWE DRIVE TRIPPED                       | RESET                             | 15:20:00 | 15:40:00 |         |
| 6     | CHP  | SCR 3 ON CC 39 | B/C NOT RUNNING DUE TO REC CHUTE JAMMING | INFORMED TO OPRN                  | 18:45:00 | 19:00:00 |         |
| 7     | CHP  | CC32           | OLR ACTED                                | RESET                             | 19:10:00 | 19:25:00 |         |
| 8     | CHP  | CC 26          | T/T CABLE GOT CUT                        | JOINT DONE                        | 18:00:00 | 18:30:00 |         |
| 9     | CHP  | S 1 AND SCR 3  | INTERCHANGED                             | BETWEEN CC 39 AND CC 40           | 14:30:00 | 18:00:00 |         |