



वी.एस.पी.  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/12/2025

Area: CHP

| Equipment                            | Job   |
|--------------------------------------|---|
| Cm 9 to JH3                          | 4*70 AL cable laid for welding machine supply |
| Tis on CC 130                        | NGEF Isolator supply cable problem rectified  |
| CC 58 T/T                            | Cable joint done                              |
| CC 108                               | BRS kept in circuit                           |
| SCR6                                 | Luff Up limit kept in circuit                 |
| CC 31, 32, 36 SCR 4, SCR5 ,S2,S3     | Greasing done                                 |
| CC 8, Tis on CC 8, CC 108, 213, 219, | PPM done                                      |
| SCR 4                                | Ht cable old joint wrapper provided by DNW    |
| IC 1                                 | Bus bar maintenance done                      |