



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 31/07/2025

Area: WT

Equipment	Job
OP 2	All drives de clutched and tested,control circuit checked,D2 O/L relay replaced
OP 6	Motor side ppm done
OP 5	After rake maintenance done
MIS	7 nos Pusher C- clamps assembling done/ made ready