वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 19/05/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 26	B/C STOPPING ON ZS CAGE STUCK UP WITH STONE	STONE REMOVED	16:15:00	16:30:00	
2	OHP	CO 87	OLR ACTED	RESET DONE	16:00:00	16:10:00	
3	OHP	CO 35	OLR ACTED (2TIMES)	RESET DONE	15:30:00	15:40:00	
4	OHP	CO 28	STOPPING ON ZS CHECKED BELT SLIPPING	INFORMED TO MECH	16:00:00	16:20:00	
5	OHP	BRC ON CO 32	B/W 1 NOT RUNNING GUIDE AND TEST ROLLER FELL DOWEN	INFORMED TO MECH	20:30:00	21:00:00	
6	OHP	CO 11 (C) DRIVE	MPCB TRIPPED	MADE ON	21:15:00	21:30:00	
7	CHP	CC 131	OLR ACTED (2TIMES)	RESET	15:15:00	15:20:00	
8	CHP	CC 54	OVER LOAD ACTED	RESET	16:05:00	16:10:00	
9	CHP	CC117	OLR TRIPPED	RESET	20:50:00	21:10:00	DUE TO JAMMING
10	CHP	CC203	NOT RUNNING MPD TRIPPED	RESET	14:50:00	15:00:00	
11	CHP	CC32 SCR 5	LT NOT TAKING PLACE PCRD OVER LAPPING	ADJUSTED	14:40:00	15:00:00	
12	CHP	CC35 SCR2	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	19:20:00	19:30:00	