



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 20/06/2025

Area: CHP

Equipment	Job
spare zss cages	2no's cages maintenance is done and made ready.
cc-25	motor and panel side ppm is done
SCR 8,R1,S3,SCR 5,SCR 4	MCC tube fixtures 10 nos replaced and improved lighting
CC 32	Chute sensor kept in ckt
CC 33	Drive end discharge chute sensor provided
SCR 8	Reclamation ZSS interlock cage provided ,wired and programmed
CC 213,215,216,217,218,220,221,222	PPM wasdone