



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 8A	B/C OLR ACTED (3TIMES)	RESET	10:00:00	10:30:00	DUE TO MATERIAL OVER LOAD
2	OHP	TBS ON CO 22	LEFT BOOM CONVEYOR OLR ACTED	RESET	10:20:00	10:30:00	
3	OHP	CC 44	OLR acted	reset it done	08:00:00	08:05:00	
4	OHP	TIS 2	failed to start	bypass in program and bypass in I/O rack	13:53:00	13:56:00	
5	CHP	CC 54	OLR ACTED	RESET	09:40:00	09:50:00	
6	CHP	CC 131	OLR ACTED (2TIMES)	RESET	07:20:00	11:20:00	
7	CHP	CC 58	OLR ACTED	RESET	10:50:00	11:00:00	
8	CHP	CC 29	F/G MPCB TRIP	MADE ON	07:35:00	07:50:00	
9	CHP	cc 105 SCR 10	B/C NOT RUNNING, zss cage stucked with coal	zss cage made free than ok	07:45:00	08:00:00	
10	CHP	CC 105 SCR 10	B/c frequently stopping, due to discharge chute jam	inform operation	08:30:00	08:35:00	
11	CHP	CC 34 scr 2	LT not working, OT acted	OT released	09:10:00	09:20:00	
12	CHP	CC 39 SCR 7	slew complaint, brake 2 fail alarm in spider	reset it done	10:00:00	10:15:00	
13	CHP	CC 38 SCR 3	slew not working, limit acted due to jamming	informed operation	12:00:00	12:10:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 32 SCR 5	luff not working	wrong complaint	12:40:00	12:45:00	
15	CHP	CC 210,203	OLR acted	reset it done	12:53:00	12:57:00	
16	WT	OC 1A BEIT DRIVE	OLR ACTED	RESET	12:50:00	13:00:00	