



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/12/2025

Area: CHP

Equipment	Job
JH C 8,9,10	4 nos 120W fixtures provided
CC 32,34,42,44,45,46,48,49,105,SCR1,10,R1	Running inspection was done
CC 222/223	One 120W LED provided, 5 nos 70W fixtures mad ready for use
SCR 8	PCRD OT cam adjusted and kept in ckt
LC 5	Room cleaning under progress
CC 28,28TT,109,36,41,S 1,CC 55	PPM was done