



वी.एस.पी.
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Shift: B

Incharge(s): Nagendra Midde,M Srinivas

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	15:40:00 16:00:00	15:50:00 16:10:00	
2	OHP	CO 29	OLR ACTED	RESET	21:25:00	21:30:00	
3	OHP	BRC ON CO 30	PCRD CABLE FELL DOWN DUE TO ONE PHASE LOOSE IN PANNEL OUT GOING	TIGHTENED AND WINDING DONE	18:40:00	19:20:00	
4	OHP	CO 111	MOTOR BURNT	REPLACED CHECKED AND GIVEN CLEARENCE	16:15:00	19:30:00	
5	OHP	CO 16	OLR ACTED	RESET	15:30:00	15:40:00	
6	OHP	CO 16	MCCB TRIPPED	MADE IT ON	16:00:00	16:15:00	
7	OHP	CO 8	OLR ACTED	RESET	19:30:00 21:00:00 21:30:00	19:40:00 21:10:00 21:40:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	15:30:00	21:00:00	8 TIMES
9	CHP	CC 51	OLR ACTED	RESET	20:35:00	20:40:00	
10	CHP	CC 54	OLR ACTED	RESET	21:10:00	21:15:00	
11	CHP	CC 125	OLR ACTED	RESET	20:35:00	20:45:00	
12	CHP	CC 108	BRS NOT RESETTING	BYPASSED	21:20:00	21:35:00	
13	CHP	SCR 5 ON CC 33	HT OLD JOINT FAILED	INFORMED TO DNW	21:55:00	22:00:00	
14	WT	OP3	BREAKER TRIPPED IN LC 2A	MADE IT ON	17:30:00	17:40:00	
15	WT	OT1	DRIVE 1 TRIPPED ON PGF1 FAULT	RESET	14:10:00	14:15:00	



वी.एस.पी.
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Shift: B

Incharge(s): Nagendra Midde,M Srinivas

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OC1A	ZSS BYPASSD	AS PER OPRN REQUEST	15:45:00	16:05:00	