



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/10/2025

Area: CHP

| Equipment | Job |
|----------------|--|
| LC 4 | Cleaning done |
| CM 18 | New zss cages welding and fabrication done 15 nos |
| CC 45 tunnel | 2 50w leds kept and improved lighting |
| CC 202 | Lighting circuit problem rectified and improved lighting |
| R1 on CC 32 | Luff down limit tested and kept in circuit |
| Scr 5 | after mech clearance winding done |
| Scr 5 | Lt end limit cable problem rectified kept in circuit |
| Scr 5 on cc 33 | LT motor 4 placed in position |