



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/10/2025

Shift: B

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|-------------------------------------|----------------------|----------------------|---------|
| 1 | OHP | DB-1 | TRIPPED ON OLR (2TIMES) | RESET DONE | 17:50:00 20:05:00 | 18:00:00 20:15:00 | |
| 2 | OHP | BRC ON CO-8A | REPORTED ALL DRIVES ARE NOT RUNNING FOUND ACB TRIPPED | ACB MADE ON THAN OK | 19:30:00 | 19:40:00 | |
| 3 | OHP | VF-23 | M1 TRIPPED ON OLR ... Y PHASE CUT IN MOTOR TB | CONNECTED ANDE TESTED | 17:25:00 | 17:40:00 | |
| 4 | OHP | CR-2 | TRIPPED ON LOCKED ROTOR FAULT | RESET AFTER CLEANING | 17:00:00 | 17:10:00 | |
| 5 | CHP | CC-51 | MPD TRIPPED (3TIMES) DUE TO FEEDING CONVEYOR STOP | RESET DONE | 16:00:00 | 19:10:00 | |
| 6 | CHP | CC-51 | TRIPPED ON OLR (5TIMES) | RESET DONE | 15:20:00 | 16:30:00 | |
| 7 | CHP | CC-132 | TRIPPED ON OLR | RESET DONE | 19:55:00 | 20:00:00 | |
| 8 | CHP | CC-54 | TRIPPED ON OLR | RESET DONE | 20:40:00 | 20:45:00 | |
| 9 | CHP | CC-32 R-1 | PLC FAULT | RESET | 14:30:00 | 15:00:00 | |
| 10 | CHP | CC-32 | TRIPPED ON OLR | RESET DONE | 16:35:00 | 16:40:00 | |
| 11 | CHP | CC-107 | TRIPPED ON OLR | RESET DONE | 17:30:00 | 17:40:00 | |
| 12 | CHP | CC-32 R-1 | BC NOT RUNNING | ZSS PROB FIXED PROPERLY THEN TESTED | 18:10:00 | 18:20:00 | |
| 13 | CHP | CC-104 SCR-9 | SLEW MCCB TRIPPED | RESET DONE | 21:10:00 | 21:30:00 | |
| 14 | IOSA | OC-25A | TRIPPED ON OLR TWICE | RESET DONE | 15:30:00 | 16:00:00 | |