



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/10/2025

Area: IOSA

Equipment	Job
OC-15A	DAMAGED FIELD DEVICE CABLES RECTIFIED AND PULLCHORD SWITCHES RECTIFICATION AND FEEDBACK CHECKING IS IN PROGRESS.
TBS	BRAKE PANEL FOR EM BRAKES SHIFTED TO E-HOUSE AND WIRING DONE FROM LT VFD PANEL TO BRAKE PANEL. WORK IS IN PROGRESS
OC-29A	ELECTRICAL HOISTS AT HEAD END , NOT GETTING OPERATED FROM PENDENT. RECTIFIED AND CHECKED.
TBS	PPM DONE ON MOTORS AND PANEL SIDE OF RIGHT AND LEFT BOOM CONVEYOR.