



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/02/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-51(C/D)	Reported tripped	OLR acted.Reset done	23:00:00	23:10:00	
2	OHP	TBS on CO-21	B/C stopping on ZSS	Wrong complaint	00:00:00	00:15:00	
3	OHP	Vf-19	Reported tripped	M-1 tripped.Reset done	00:00:00	00:10:00	
4	OHP	Co-20	Reported ZSS acting	Belt snapped	01:10:00	01:20:00	Informed to operation
5	CHP	CC-51	MPD tripped	Reset done (7 times)	23:00:00	05:15:00	
6	CHP	CC 132	Reported P/C acted	P/C found acted.Reset done	04:30:00	04:35:00	