



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/07/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO48	Conveyor not running found motor winding failed meggar values are zero (phase to earth), Bearing also jammed and struck up	Available spare motor changed , direction checked and given clearance no load amps 11Amps and at load condition 13 Amps	00:30:00	04:30:00	Motor fan cover is to be fixed and Mono rail hoist not working due to struck up off rope in the rotating drum needs repair, delay is due to manual shifting of motor from CO47 area to CO48 area as mono rail choist not working
2	OHP	CO26	Red found over load acted	Reset done	23:45:00	23:50:00	
3	OHP	CO35	OLR acted	Reset done	23:30:00	23:35:00	
4	OHP	BRC on CO31	BC drive tripping found CJD acted due to material jamming	informed to operation	05:00:00	05:20:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/07/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
5	OHP	CO6a	BRS by passed due to nonsense tripping and not able to reset	Bypassed and informed to A shift	23:00:00	23:05:00	may check further please
6	CHP	CC52	Motor tripped on over load 4 times	reset done	23:55:00	00:00:00	01.50am to 1.55am:02.05am to 02.10am and 02.50am to 02.55am
7	CHP	CC54	Over load acted 4 times	Reset done	01:40:00	01:45:00	01.55am to 02.00am:02.10am to 02.15am and 02.25am to 02.30am



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 28/07/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
8	CHP	SCR3 on CC38	BC not running found panel is in off condition and R1 is chattering	Provided high from control MCB	22:40:00	23:15:00	Ckt may check in g shift and panel is in off condition and tag also observed but no record of shut down may check and clarify further please
9	CHP	S2 on CC36	PCRd cable fell on ground found cable guide got struck	cable winding done and informed to mechanical regarding cable guide	23:20:00	23:55:00	
10	CHP	CC125	Over load acted	Reset done	00:55:00	01:00:00	
11	CHP	CC111	ZSS complaint	found ok	00:30:00	00:55:00	
12	CHP	SCR3 on CC38	BC ZSS cage got struck up	ZSS by passed in module	02:10:00	02:35:00	Needs replacement of ZSS cage informed to A shift
13	WT	OP2	Not moving found D5 over load acted during coupling time	reset done	02:30:00	02:40:00	