



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/10/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-19	LT NOT TAKING PLACE FOUND DRIVE TRIP	RESET DONE	11:15:00	11:30:00	
2	OHP	CR-2A	REPORTED SHOWING R/OIL FLOW FAULT INDICATION	FAULT RESET DONE THAN OK	12:40:00	13:00:00	
3	CHP	CC-51	OLR ACTED (2TIMES)	RESET DONE	11:00:00 11:50:00	11:10:00 12:00:00	
4	CHP	CC-51	MPD TRIP (10TIMES) FEEDING CONVEYOR STOP	RESET DONE	07:30:00	13:30:00	
5	CHP	CC-54	TRIPPED ON OLR (10TIMES)	RESET DONE	07:30:00	13:30:00	
6	CHP	CC-33 SCR-5	LT NOT TAKING PLACE FOUND DRIVE TRIP	RESET DONE	06:35:00	06:45:00	DUE TO TRACK JAMMING INFORMED TO OPERATION
7	CHP	CC-223	BREAKER TRIP	MADE IT ON	07:25:00	07:30:00	
8	CHP	CC-33	TRIPPED ON OLR	RESET DONE	07:10:00	07:20:00	
9	CHP	CC-37	REPORTED HEALTHY STOPPING CHECKED AND FOUND ZSS CAGE STUCK	ZSS CAGE REPLACED WITH NEW THAN OK	10:15:00	10:35:00	
10	CHP	CC-112 SCR-8	B/C TRIPPED ON OLR	RESET DONE	13:10:00	13:15:00	
11	CHP	CC-33 SCR-5	LT DRIVE TRIP	RESET DONE	13:10:00	13:15:00	