



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 30/01/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 32 LT	PCRD O/T ACTED	RELEASED	07:30:00	07:40:00	
2	OHP	CO 26	OLR ACTED	RESET	08:30:00	08:40:00	
3	OHP	WBR ON CO 29	MAIN CONTROL MCB TRIP AND I/O CARD CONTROL MCB IN I/O RACK TRIPPED	MADE IT ON	08:55:00	09:20:00	
4	OHP	CO 9	MOTOR BURNT	CHANGING UNDER PROCESS	10:00:00	14:00:00	
5	OHP	AF 4	DRIVE TRIPPED	RESET	06:30:00	06:35:00	
6	OHP	VS 1A	OLR ACTED	RESET	12:15:00	12:20:00	
7	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	06:40:00	13:30:00	6 TIMES
8	CHP	CC 54	OLR ACTED	RESET	07:00:00	08:30:00	4 TIMES
9	CHP	YARD MACHINES	NOT RUNNING DUE TO POWER DIP	POWER CHARGED AND GIVEN CLEARENCE	11:00:00	11:30:00	
10	CHP	CC 28	OLR ACTED	RESET	06:40:00	06:50:00	
11	CHP	CC 107	OLR ACTED	RESET	09:10:00	09:20:00	
12	CHP	CC 48	DRIVE TRIPPED	RESET	11:30:00	11:40:00	
13	CHP	COB5	CONTROL MCB TRIPPED LC6 I/ RACK	MADE IT ON	12:45:00	13:00:00	
14	WT	OT4	DRIVE 2 TRIP	RESET	11:30:00	11:40:00	