



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 20	LT not taking place,vfd drive failed	drive replace with delta drive of cp1 ,drive is faulty	23:00:00	06:30:00	still pending
2	OHP	wobr on co 26	bc olr atced	reset	04:50:00	05:00:00	
3	OHP	co 62	olr acted	reset	23:30:00	23:35:00	
4	CHP	CC 34 SCR1	b/w not working,olr acted	reset	04:55:00	05:00:00	