



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/12/2025

Area: WT

Equipment	Job
OP 4	D2 tyre fixed by Mech. kept in circuit
E O T Crane(O)	Aux. Hoist rope changed by mechanical., gravity limit fixed and kept in circuit
CT 2 Area	350W LED replaced at BAY and 1 no 400W S V fitting rectified
CC 3 Area	Lighting job done one no 200W LED installed
CP 1 to 4	Inspection done@ parking zone
OP 2 to 8	Inspection done@ parking zone
OP 1 and 7	After rake maintenance done