



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2025

Incharge(s): V Balaji Naik

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|--|----------|----------|---------|
| 1 | OHP | CC117 | Motor trip due to over load | Reset done | 16:30:00 | 16:50:00 | |
| 2 | OHP | TT2 | LT not working found MPCB trip | Reset done | 19:30:00 | 19:40:00 | |
| 3 | CHP | RG2 flap gate | Flap gate motor trip | Reset done | 20:00:00 | 20:05:00 | |
| 4 | CHP | CC54 | Motor over load trip due to over load | Reset done | 20:45:00 | 20:50:00 | |
| 5 | CHP | CC31 Flap gate | Flap gate motor trip | Reset done | 21:00:00 | 21:05:00 | |
| 6 | CHP | CC51 | ZSS acted found over load | Informed to operation and mechanical | 16:00:00 | 16:01:00 | |
| 7 | CHP | SCR10 on CC105 | BC not running found MPR tripped fault EF | Reset done | 14:25:00 | 14:35:00 | |
| 8 | CHP | SCR5 on CC32 | BC not running found Over load relay tripped | Reset done | 14:55:00 | 15:05:00 | |
| 9 | CHP | SCR4 on CC33 | Slew not working XMD panel reset done | Reset done | 15:20:00 | 15:40:00 | |
| 10 | CHP | SCR7 on CC36 | LT not working found OT limit acted and rev contactor struck | Limit released and contactor made free | 15:40:00 | 16:15:00 | |
| 11 | CHP | SCR1 on CC35 | LT and slew not working found 30 degree acted and LT drive tripped | LT drive reset done and Reset done | 16:40:00 | 17:00:00 | |
| 12 | CHP | CC36 | BRS not healthy sensor receiver fault | new sensor fixed and bypass removed | 18:40:00 | 19:00:00 | |
| 13 | CHP | SCR3 on CC38 | Mode not changing found signal missing radio modem ping done | Machine LT done toward DE side then ok | 19:30:00 | 19:40:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2025

Shift: B

Incharge(s): V Balaji Naik

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|-------------------------------------|----------|----------|---------|
| 14 | CHP | SCR7 on CC36 | LT not moving found Over tension limit acted | Over tension limit released then ok | 19:40:00 | 19:55:00 | |
| 15 | CHP | CC202 | Over load trip | Reset done | 19:55:00 | 20:00:00 | |