



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/07/2025

Area: OHP

Equipment	Job
losp1 ; VS airblasters	plc operation is checked , sequential timer needs to be programmed as per requirement.
losp-2	motor and panels ppm is done
co-32	spare mccb feeder is being made ready.
tbs-3 on co-21	running inspection is done
wbr-1 on co-26	io rack is installed and charged with 110v supply.
cbms-6a hoist,co-6a	motor and panel ppm is done
brc-2 on co-32	ppm is done
co-3b,15,tt-2,8,11	motor and panel JB's ppm is done