



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/12/2025

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|--|----------|----------|---------|
| 1 | OHP | BRC ON CO-28 | REPORTED B/W-2 NOT RUNNING CHECKED AND FOUND MULTI DISK DAMAGED | INFORMED TO MECHANICAL | 06:50:00 | 07:10:00 | |
| 2 | OHP | TBS ON CO-22 | REPORTED LBC STOPPING ON ZSS FOUND ZSS CAGE STUCK UP WITH STONE | REMOVED THAN OK | 07:50:00 | 08:05:00 | |
| 3 | OHP | CO-26 | TRIPPED ON OLR | RESET DONE | 13:10:00 | 13:20:00 | |
| 4 | OHP | CO-111 B/D | TRIPPED ON OLR | RESET DONE | 11:00:00 | 11:05:00 | |
| 5 | OHP | RSCO-10A | STOPPING ON ZSS FOUND ZS PROBE FIXING CHECK NUT LOOSE | ZSS PROBE GAP ADJUSTED AND CHECK NUT TIGHT THAN OK | 12:40:00 | 12:55:00 | |
| 6 | OHP | CC-51 | MPD TRIPPED FEEDING CONVEYOR STOP (16 TIMES) | RESET DONE | 07:10:00 | 13:35:00 | |
| 7 | CHP | CC-53 | MPCB TRIPPED | MPCB MADE ON THAN OK | 13:15:00 | 13:30:00 | |
| 8 | CHP | CC-51 | TRIPPED ON OLR (2TIMES) | RESET DONE | 09:10:00 | 09:20:00 | |
| 9 | CHP | CC-130 | REPORTED NOT RUNNING CHECKED AND FOUND VFD DRIVE CONTROL WIRE LOOSE CONNECTION | RECTIFIED THAN OK | 12:15:00 | 13:15:00 | |
| 10 | CHP | CC-104 SCR-9 | REPORTED SLEW NOT WORKING LIMIT ACTED DUE TO JAMMING INFORMED TO OPERATION | AFTER CLEAR THE MATERIAL LIMIT RELEASED THAN OK | 07:30:00 | 07:50:00 | |
| 11 | CHP | CC-125 | TRIPPED ON OLR | RESET DONE | 08:50:00 | 08:55:00 | |
| 12 | IOSA | BRC | CT END LIMIT ACTED | RELEASED | 07:00:00 | 07:10:00 | |