



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/11/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR	RESET DONE	09:20:00 13:20:00	09:30:00 13:30:00	
2	OHP	CO-32 BRC	LT NOT WORKING	PCRD OT ACTED ... RELEASED	07:30:00	07:45:00	
3	CHP	CC-47	ZSS PROBLEM	PROB CABLE FIXED PROPERLY	08:30:00	08:45:00	
4	CHP	CC-125	TRIPPED ON OLR	RESET DONE	10:00:00	10:10:00	
5	CHP	CC-45	TRIPPED ON OLR	RESET DONE	10:40:00 11:05:00 11:50:00	10:45:00 11:10:00 11:55:00	
6	CHP	CC-34 SCR-1	SLEW 30 DEGREE LIMIT ACTED	RELEASED	12:30:00	12:40:00	
7	CHP	CC-26	FLAP GATE MPCB TRIPPED	MADE ON	09:10:00	09:20:00	
8	CHP	CC-54	TRIPPED (8 TIMES )	RESET DONE	07:10:00	13:30:00	