



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment        | Problem              | Action                     | From                 | To                   | Remarks               |
|-------|------|------------------|----------------------|----------------------------|----------------------|----------------------|-----------------------|
| 1     | OHP  | co 84            | tripped on olr       | reset 2times               | 09:30:00<br>10:50:00 | 09:40:00<br>11:00:00 |                       |
| 2     | CHP  | cc 51            | tripped on olr       | reset done 10times         | 07:00:00             | 13:40:00             | feeding<br>conv. stop |
| 3     | CHP  | cc 45            | tripped on olr       | reset                      | 08:30:00             | 08:35:00             |                       |
| 4     | CHP  | cc 50            | brs acting           | bypassed for ope. request  | 10:45:00             | 10:50:00             | again kept<br>in ckt  |
| 5     | IOSA | brc on oc<br>15a | ct not taking place/ | parameters changed/then ok | 09:00:00             | 09:20:00             |                       |