



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	Reported tripped	OLR acted.Reset done	19:20:00 21:10:00	19:25:00 21:20:00	
2	OHP	CO-35	Reported tripped	OLR acted.Reset done	20:00:00	20:05:00	
3	OHP	RSCO-6A(C/D)	Reported tripped	OLR acted due to track jamming.Reset done	20:00:00	20:20:00	
4	CHP	Cc28	Flap gate tripped	OLR acted.Reset done	14:30:00	14:40:00	
5	CHP	Cc117	Reported tripped	OLR acted.Reset done	17:05:00	17:20:00	
6	CHP	CC 51	Reported tripped	MPD tripped(9 times)	15:15:00	21:20:00	
7	CHP	Cc 54	Reported tripped	OLR acted.Reset done	20:25:00 21:05:00	20:30:00 21:10:00	
8	CHP	Cc 131	Reported tripped	OLR acted.Reset done	20:50:00	20:55:00	
9	CHP	CC 105	YARD ZSS adjustment to be done	Adjustment done	15:30:00	15:50:00	
10	CHP	CC 45	Reported tripped	OLR acted.Reset done	17:40:00 21:05:00	17:50:00 21:10:00	