



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 03/07/2025

Area: IOSA

| Equipment       | Job  |
|-----------------|--|
| OC-21A and 23A  | LIGHTING DB CLEANING , TIGHTNESS AND RECTIFICATION DONE.   |
| 1-142LC-2       | HOUSEKEEPING DONE IN PLC AND MCC ROOMS   |
| OC-23A          | ELECTRICAL HOIST RECTIFIED AND CHECKED.  |
| OC-11A          | RUNNING AND SPARE MOTORS COVERED WITH BELT PIECE AS RAIN WATER FALLING ON MOTORS DUE TO SHED ROOF SHEETS GOT RUSTED AND DAMAGED. |
| OC-27A          | PPM DONE ON ZONE-2 and 3 FIELD DEVICES .   |
| WOBR ( L and T) | ZSS OF MACHINE TO YARD TAKEN IN LINE AND FEEDBACK AND INTERLOCK CHECKED.   |
| OJH-11A and 12A | ELECTRICAL HOIST MOTOR MPCB REPLACEMENT.   |
| OC-19A          | DE-WATERING PUMPS CHECKED IN AUTO.   |