



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 8A	B/C OLR ACTED	RESET	16:10:00 18:20:00	16:30:00 18:30:00	
2	OHP	BRC ON CO 32 B/W	CONTROL MCB IS IN OFF CONDITION	MADE IT ON	20:15:00	20:30:00	
3	OHP	CC 25	OLR ACTED	RESET	21:30:00	21:40:00	
4	CHP	CC 131	OLR ACTED	RESET	16:15:00	16:20:00	
5	CHP	CC 54	OLR ACTED	RESET	16:45:00	16:50:00	
6	CHP	CC 47 ZSS ACTING	BELT SLOW	INFORMED TO OPRN	18:15:00	18:25:00	
7	WT	CO 3	OLR ACTED	RESET	15:30:00	15:40:00	