



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/06/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment     | Problem   | Action  | From                             | To                               | Remarks |
|-------|------|---------------|---|---|----------------------------------|----------------------------------|---------|
| 1     | OHP  | co-6a         | BRS NOT RESETTING                               | RECEIVER RETURN WIRE JOINT PROBLEM .. RECTIFIED | 15:00:00                         | 15:20:00                         |         |
| 2     | OHP  | CO-29         | OLR ACTTING FREQUENTLY DUE TO DECKSHEET JAMMING | INFORMED OPERATION ... RESET DONE               | 18:00:00                         | 21:00:00                         |         |
| 3     | OHP  | CR-3          | LUBRICATION OIL FLOW SWITCH PROBLEM             | OPENED AND CLEANED                              | 18:30:00                         | 19:00:00                         |         |
| 4     | OHP  | CO-48         | TRIPPED ON OVER LOAD                            | RESET DONE                                      | 18:00:00                         | 18:10:00                         |         |
| 5     | OHP  | CO-32 BRC     | BW-2 STOPPING ON ZSS                            | T4 TIMER COIL REMOVED                           | 21:30:00                         | 22:00:00                         |         |
| 6     | OHP  | CO-27A        | BRS KEPT IN CKT                                 | DONE  | 20:30:00                         | 20:35:00                         |         |
| 7     | OHP  | CO-21         | BRS BYPASS REQUEST                              | BYPASSED  | 18:00:00                         | 18:10:00                         |         |
| 8     | CHP  | CC-131        | TRIPPED ON OLR                                  | RESET DONE                                      | 19:25:00<br>20:20:00<br>21:30:00 | 19:30:00<br>20:25:00<br>21:35:00 |         |
| 9     | CHP  | CC-51A        | TRIPPED ON OVER LOAD                            | RESET DONE                                      | 14:45:00                         | 14:50:00                         |         |
| 10    | CHP  | CC-53         | TRIPPED ON OVER LOAD                            | RESET DONE                                      | 20:55:00                         | 21:00:00                         |         |
| 11    | CHP  | CC-12         | BRS BYPASSED DUE TO DUST ON OPERATION REQUEST   | BYPASSED  | 15:30:00                         | 15:35:00                         |         |
| 12    | CHP  | CC-32 SCR-5   | LT NOT WORKING                                  | M3 MPCB TRIPPED ... RESET DONE                  | 16:00:00                         | 16:32:00                         |         |
| 13    | CHP  | CC-104 SCR-10 | SIGNAL PROBLEM                                  | MACHINE LT DONE THEN OK                         | 18:15:00                         | 18:35:00                         |         |



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/06/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment        | Problem  | Action                | From     | To       | Remarks |
|-------|------|------------------|--|-----------------------|----------|----------|---------|
| 14    | CHP  | CC-38<br>SCR-3   | SLEW NOT WORKING (OPERATOR FAULT)<br>BC IS RUNNING WHILE CHANGING BOOM<br>POSITION FROM GVM TO OHP SIDDE | INFORMED OPERATOR     | 16:00:00 | 16:15:00 |         |
| 15    | CHP  | CC-33<br>SCR-4   | SLEW NOT WORKING (WRONG COMPLAINT)   | TESTED FOUND OK       | 16:00:00 | 16:20:00 |         |
| 16    | CHP  | CC-105<br>SCR-10 | SLEW BW NOT WORKING  | OIL LOW INFORMED MECH | 21:25:00 | 21:45:00 |         |
| 17    | IOSA | IOSA TBS         | LT LMIT ACTED DUE TO PLANTS  | RESET                 | 14:55:00 | 15:10:00 |         |