



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/07/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|---|--|----------------------|----------------------|--|
| 1 | OHP | CO 29 | OLR ACTED | RESET | 17:50:00 | 18:00:00 | |
| 2 | OHP | CO 26 | OLR ACTED | RESET | 21:20:00 | 21:30:00 | |
| 3 | OHP | WOBR-4 on CO-34 | LT Auto Forward to be bypassed | LT Auto Bypass done in I/O rack | 20:10:00 | 20:20:00 | Operation request given in interlock group |
| 4 | CHP | CC 27A | TT DOUBLE INDICATION ON CC39 AND CC40 | TT PROPERLY PLACED THEN OK | 15:20:00 | 15:34:00 | Operator did not place TT properly at proximity switch |
| 5 | CHP | CC 112 SCR 8 | NO POWER CHECKED I/C 1 TRIP IN LBDS DUE TO EARTH FAULT IN CC 213 IO PANEL | CC 213 BREAKER RACK OUT THAN I/C 1 AND CC 112 SCR8 POWER CHARGED THAN OK | 15:00:00 | 15:45:00 | Snake found in CC-213 panel. NO machine on that bed |
| 6 | CHP | CC 31 | OLR ACTED | RESET | 20:10:00 | 20:20:00 | |
| 7 | CHP | CC-222 | NOT HEALTHY IN REMOTE SELECTION E/STOP PUSH BUTTON PROBLEM | E/STOP PUSH BUTTON REPLACED WITH NEW | 16:40:00 | 16:50:00 | |
| 8 | CHP | CC-39 | Reported not healthy | Olr acted due to over material on belt. Reset done | 21:30:00 | 21:40:00 | |
| 9 | CHP | CC-54 | Reported not healthy | Olr acted due to over material on belt | 15:40:00 20:55:00 | 15:55:00 21:00:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/07/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------|----------------------|--|----------|----------|---------|
| 10 | CHP | CC-52 | Reported not healthy | OLR acted due to over material on belt | 21:00:00 | 21:10:00 | |
| 11 | WT | SCO-1A (C) DRIVE | OLR ACTED | RESET | 18:30:00 | 18:40:00 | |